

Town of LaGrange Wastewater Treatment Facilities

402 Nursery St
LaGrange, IN 46761
260-463-2042

Sewer Tap Permit Requirements-Residential

All building sewer service laterals shall be SDR 35 PVC pipe conforming to ASTM D 3034. Joints shall be gasket push-on, compression type conforming to ASTM D 3212. Gaskets shall conform to ASTM F 477. No. 8 crushed stone shall be used as bedding to a minimum of twelve (12) inches above all piping and fittings from the public sewer to the outer edge of the easement or right away. NO. 8 crushed stone or approved equal shall be used as bedding to a minimum of six (6) inches above all piping and fittings for the remainder of building sewer service lateral.

Building sewer service laterals shall connect to the public sewer at a mainline fitting. Direct connections to manholes shall not be permitted without prior approval from the wastewater superintendent.

Building sewers shall have a wye cleanout located within three feet of building's exterior wall and extended to grade.

Cleanouts installed under concrete or asphalt paving shall be made accessible by yard boxes or extended flush with paving with approved materials and be adequately protected.

Use of sewer tap saddles is not permitted without prior approval of the Wastewater Superintendent.

It shall be the responsibility of the Holder of the Sewer Tap Permit to notify the LaGrange Wastewater Department that building sewer service laterals and taps are available for inspection. The LaGrange Wastewater Department will conduct inspections from 7:00 AM to 3:00 PM Monday through Friday except on observed Town holidays. The Holder of the Sewer Tap Permit or their representative must notify the LaGrange Wastewater Department a minimum of two (2) hours prior to inspection. The building sewer service shall be fully exposed from the foundation to the point of connection with the public sewer and proper bedding material shall be on-site.

Clear water connections to any portion of the building sewer service or public sewer system is strictly prohibited. Some examples of clear water sources are roof drains, perimeter drains, and basement or crawl space sump pumps.